



Member of the FM Global Group

FM Approvals  
1151 Boston Providence Turnpike  
P.O. Box 9102 Norwood, MA 02062 USA  
T: 781 762 4300 F: 781-762-9375 www.fmapprovals.com

# CERTIFICATE OF COMPLIANCE

## HAZARDOUS LOCATION ELECTRICAL EQUIPMENT PER CANADIAN REQUIREMENTS

This certificate is issued for the following equipment:

**8579/22-b. Plug.**

**8579/41-b. Receptacle.**

DIP / II / 1 / G / Ta = -30 °C to +40 °C; I / 1 / Ex d e IIC / T6 Ta = -30 °C to +40 °C  
b = Configuration 404, 405, 406, 407, 409, 412, 504, 505, 506, 507, 509, and 512.

**8581/22-b. Plug.**

**8581/41-b. Receptacle.**

DIP / II / 1 / EFG / Ta = -30 °C to +40 °C; I / 1 / Ex d e IIC / T5 Ta = -30 °C to +40 °C  
b = Configuration 404, 405, 406, 407, 409, 412, 504, 505, 506, 507, 509, and 512.

### Equipment Ratings:

The Series 8579/... is dust ignition protected for Class II, Division 1, Group G, Ta = -30 °C to +40 °C, Ex d e IIC T6 Ta = -30 °C to +40 °C; indoor and outdoor hazardous locations.

The Series 8581/... is dust ignition protected for Class II, Division 1, Group G, Ta = -30 °C to +40 °C, Ex d e IIC T5 Ta = -30 °C to +40 °C; indoor and outdoor hazardous locations.

### FM Approved for:

R STAHL Schaltgeräte GmbH  
74638 Waldenburg GERMANY

To verify the availability of the Approved product, please refer to [www.approvalguide.com](http://www.approvalguide.com)

This certifies that the equipment described has been found to comply with the following Approval Standards and other documents:

CSA C22.2 No. 60079-0	2007
CSA C22.2 No. 60079-1	2007
CSA C22.2 No. 60079-7	2003
CSA C22.2 No. 94	R2006
CSA C22.2 No. 60529	2005


Original Project ID: 0R6A2.AX  
Canadian Project ID: 3050350

Approval Granted: September 6, 2013

Subsequent Revision Reports / Date Approval Amended

Report Number	Date	Report Number	Date
---------------	------	---------------	------

FM Approvals LLC

  
Robert L Martell  
Assistant Vice President

September 6, 2013  
Date