

CERTIFICATE OF CONFORMITY

1. HAZARDOUS LOCATION COMPONENT PER CANADIAN REQUIREMENTS

2. **Certificate No:** **FM23CA0033U**
3. **Component:** **Series 8080**
(Type Reference and Name) **Control Switch**
4. **Name of Listing Company:** **R. STAHL Schaltgeräte GmbH**
5. **Address of Listing Company:** **Am Bahnhof 30, D-74638 Waldenburg (Württ.),
Germany**

6. The examination and test results are recorded in confidential report number:

PR466187 dated 27 June 2023

7. FM Approvals LLC, certifies that the component described has been found to comply with the following Approval standards and other documents:

CSA C22.2 No. 14:2018, CSA C22.2 No. 60079-0:2019, CSA C22.2 No. 60079-1:2016,
CSA C22.2 No. 60079-7:2016, CSA C22.2 No. 65:2021

8. The sign 'U' placed after the certificate number indicates that this certificate must not be mistaken for a certificate for equipment or a protective system. This certificate may only be used as the basis for the certification of equipment or a protective system. This certificate is issued to the manufacturer also intended to be the holder of the equipment certificate which includes this component.
9. This certificate relates to the design, examination and testing of the products specified herein. The FM Approvals surveillance audit program has further determined that the manufacturing processes and quality control procedures in place are satisfactory to manufacture the product as examined, tested and Approved.

10. Component Ratings:

Flameproof "d" enclosure with Increased Safety terminals "e"

11. The marking of the component shall include:

Ex db eb IIC Gb
CI I, Div 2 per CEC J18-150

Certificate issued by:



J.E. Marquedant
VP, Manager - Electrical Systems

27 June 2023

Date

To verify the availability of the Approved product, please refer to www.approvalguide.com

THIS CERTIFICATE MAY ONLY BE REPRODUCED IN ITS ENTIRETY AND WITHOUT CHANGE

FM Approvals LLC, 1151 Boston-Providence Turnpike, Norwood, MA 02062 USA
T: +1 (1) 781 762 4300 F: +1 (1) 781 762 9375 E-mail: information@fmapprovals.com www.fmapprovals.com

F 331 (Apr 21)



SCHEDULE

Canadian Certificate Of Conformity No: FM23CA0033U



12. Description of Component:

The Series 8080 explosion-protected contact element for the switching of auxiliary, control and signal circuits. The contact element is an Ex Component which may only be used as a basis of an Ex Equipment certificate for equipment or protective system of EPL Gb or Class I, Division 2.

Model Code:

8080/1-cd. Explosion Protected Control Switch.

c = Contact type; 1, 2, 3, 4, or 5.

d= Additional variants not affecting FM Approval.

13. Schedule of Limitations:

1. Contacts rated 250 VAC / 10 A General purpose
2. The Series 8080 has an ambient temperature range of $-50\text{ °C} \leq T_a \leq +70\text{ °C}$.
3. The Series 8080 has a service temperature range of $-60\text{ °C} \leq T_s \leq +100\text{ °C}$.
4. Field wiring conductors shall be rated not less than 75 °C .
5. The flameproof enclosure cannot be repaired.
6. The Series 8080 shall be protected from exposure to ultraviolet light.
7. For EPL Gb applications, the Series 8080/1 shall be installed in an increased safety "eb" enclosure.
8. For Class I, Division 2 applications, the connections to the Series 8080/1 may be made in a general purpose enclosure using standard connection methods. Increased safety "eb" termination methods are permitted, but are not required.
9. With a rated voltage greater than 175 VAC, the metal plunger shall not come in contact with electrically conductive parts.
10. In a 10 A application, the maximum rise for the determination of temperature class is 27 K with a limiting temperature in the final application of 80 °C for T6, 95 °C for T5, or 105 °C for T4.

14. Test and Assessment Procedure and Conditions:

This Certificate has been issued in accordance with FM Approvals Canadian Certification Scheme.

15. Schedule Drawings

A copy of the technical documentation has been kept by FM Approvals.

16. Certificate History

Details of the supplements to this certificate are described below:

Date	Description
27 June 2023	Original Issue.

To verify the availability of the Approved product, please refer to www.approvalguide.com

THIS CERTIFICATE MAY ONLY BE REPRODUCED IN ITS ENTIRETY AND WITHOUT CHANGE

FM Approvals LLC, 1151 Boston-Providence Turnpike, Norwood, MA 02062 USA

T: +1 (1) 781 762 4300 F: +1 (1) 781 762 9375 E-mail: information@fmapprovals.com www.fmapprovals.com

F 331 (Apr 21)

