

	ertification Sche	CTROTECHNICAL eme for Explosive the IECEx Scheme visit www.ie	Atmospheres
Certificate No.:	IECEx PTB 06.0056U	issue No.:1	Certificate history: Issue No. 1 (2012-1-27) Issue No. 0 (2007-3-9)
Status:	Current		ISSUE NO. 0 (2007-3-9)
Date of Issue:	2012-01-27	Page 1 of 4	
Applicant:	R. STAHL Schaltgerät Am Bahnhof 30 74638 Waldenburg (Würt Germany		
Electrical Apparatus: Optional accessory:	Fuse, type 8560/		
Type of Protection:	Increased safety "e", En	ncapsulation "m"	
Marking:	Ex em II resp. Ex em I		
Approved for issue on b Certification Body:	ehalf of the IECEx	Dr. U. Johannsmeyer	
Position:		Head of Department "Intrinsic	Safety and Safety of Systems"
Signature: (for printed version)			
Date:			
2. This certificate is not		uced in full. e property of the issuing body. be verified by visiting the Officia	al IECEx Website.
Certificate issued by:			
Physikalisch-Technische Bundesanstalt (PTB) Bundesallee 100 38116 Braunschweig Germany			



Certificate No .:	IECEx PTB 06.0056U		
Date of Issue:	2012-01-27	Issue No.: 1	
		Page 2 of 4	
Manufacturer:	R. STAHL Schaltgeräte Am Bahnhof 30 74638 Waldenburg (Württ Germany		
Additional Manufacturing lo (s):	cation		
This certificate is issued as verification that a sample(s), representative of production, was assessed and tested and found to comply with the IEC Standard list below and that the manufacturer's quality system, relating to the Ex products covered by this certificate, was assessed and found to comply with the IECEx Quality system requirements. This certificate is granted subject to the conditions as set out in IECEx Scheme Rules, IECEx 02 and Operational Documents as amended.			
	d any acceptable variations to it sp omply with the following standards:	ecified in the schedule of this certificate and the identified	
IEC 60079-0 : 2004 Edition: 4.0			
IEC 60079-18 : 1992 Edition: 1	: 1992 Electrical apparatus for explosive gas atmospheres - Part 18: Encapsulation 'm'		
IEC 60079-7 : 2001 Edition: 3	EC 60079-7 : 2001 Electrical apparatus for explosive gas atmospheres - Part 7: Increased safety 'e'		
This Certificate does not indicate compliance with electrical safety and performance requirements other than those expressly included in the Standards listed above.			
TEST & ASSESSMENT REPORTS: A sample(s) of the equipment listed has successfully met the examination and test requirements as recorded in			

Test Report: DE/PTB/ExTR06.0088/00

Quality Assessment Report:

DE/BVS/QAR10.0002/02



Certificate No .:

IECEx PTB 06.0056U

Date of Issue:

2012-01-27

Issue No.: 1

Page 3 of 4

Schedule

EQUIPMENT:

Equipment and systems covered by this certificate are as follows:

Description of equipment

The fuse, type 8560/..., is used for the protection of electrical circuits in potentially explosive atmospheres. It has to be installed into an enclosure with type of protection Increased Safety "e", where at least degree of protection IP54 is maintained. The fuse may be used with or without cover.

Nomenciature			
Fuse	Туре	8560/ab	
a, b	51 = G-Fuse (5x20) 250 V		
	61 = G-Fuse (5x30) 500 V		
	71 = TR-5 Fuse 250 V		
Technical data			

Rated voltage	up to	500 V
Rated current	up to	6.3 A
Rated cross section		2 x 2.5 mm ²
Fuse characteristic		F (fast), M (medium), T (slow)

Breaking capacity (I_{Δ})

	F		М		Т	
	I ≤ 3.15 A	I _A = 35 A	l ≤ 1.25 A	I _A = 80 A	I ≤ 3.15 A	I _A = 35 A
250 V	I = 4.0 A	I _A = 40 A			I = 4.0 A	I _A = 40 A
250 V	I = 5.0 A	I _A = 50 A			I = 5.0 A	I _A = 50 A
	I = 6.3 A	I _A = 63 A			I = 6.3 A	I _A = 63 A
500 V			I ≤ 1.25 A	I _A = 50 A		

Ambient temperature

Ambient temperature	Rated current	Can be used in temperature class
T _a ≤ 56 °C	≤ 4.0 A	Т6
T _a ≤ 70 °C	≤ 4.0 A	Т5
T _a ≤ 46 °C	≤ 5.0 A	Т5
T _a ≤ 70 °C	≤ 6.3 A	Τ4

The fuses maximum permissible temperature is 120 °C. This is due to the characteristics of materials used. Special Requirements

1. The fuse may only be installed into certified enclosures (min. IP54).

2. The fuse may be used in a temperature range of -50 °C to +70 °C. The exact assignment is to be seen from the operating instructions.

3. The breaking capacity of the fuse-link has to be the same as or larger than the maximum expectable short circuit current at the module position (usually 1500 A). Should the breaking capacity of the fuse deviate from 1500 A, the real breaking capacity of the fuse is to be seen from the operating instructions. The equipment, in which this fuse is used, is to be marked with the real breaking capacity of the fuse used.

4. The fuse type 8560/51 and type 8560/71 (250 V) may be lined up directly without cover.

5. For the fuse type 8560/61 (500 V) without cover, a minimum distance of 3 mm between the fuses is maintained. Should larger clearances and creepage distances be required, suitable separator plates have to be attached between the fuses.

6. If fuses are installed or built on electroconductive enclosures or walls, the following minimum distance to the fuse must be maintained:

3 mm for type 8560/51 and type 8560/71

5 mm for type 8560/61

CONDITIONS OF CERTIFICATION: NO



Certificate No .:

IECEx PTB 06.0056U

Date of Issue:

2012-01-27

Issue No.: 1

Page 4 of 4

DETAILS OF CERTIFICATE CHANGES (for issues 1 and above):

New QAR