



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

No.: 2021312308000114

Applicant	R. STAHL Schaltgeräte GmbH
Address	Am Bahnhof 30, 74638 Waldenburg, Germany
Manufacturer	R. STAHL Schaltgeräte GmbH
Address	Am Bahnhof 30, 74638 Waldenburg, Germany
Production Factory	R. STAHL Schaltgeräte GmbH
Production Address	Am Bahnhof 30, 74638 Waldenburg, Germany
Product	Wall Socket and Coupler Socket
Model/Type	8571/**-***-*(-*)
Ex marking	Ex db eb IIC T6/T5 Gb, Ex tb IIIC T76°C Db
Reference Standards	GB/T 3836.1-2021, GB/T 3836.2-2021, GB/T 3836.3-2021, GB/T 3836.31-2021

Certification mode Type Test + Initial Factory Inspection + Post-Certification Surveillance

The sample(s) is verified and certified according to CNCA-C23-01: 2019 *China Compulsory Certification Implementation Rule on Explosion Protected Electrical Product* and CNEX-C2301-2019 *Guideline of China Compulsory Certification Implementation Rule on Explosion Protected Electrical Product*.

See Annex for the detailed product information (5 pages).

Initial issue date: 2022-02-13

Issued date: 2023-04-24

Valid to: 2027-02-12

The Validity of this certificate is maintained through the regular supervision of the issuing authority during the validity period.

Where any discrepancy arises between the English translation and the Original Chinese version, the Chinese version shall prevail.

Director:



Nanyang Explosion Protected Electrical
Apparatus Research Institute Co.,Ltd.



<http://www.ccc-cnex.com>
ccc.china-ex.com

Add: No. 20, North Zhongjing Road, Nanyang, Henan, P. R. China P.C.: 473008
Tel: 0377-63239734 Email: ccc@cn-ex.com

CN 0001958



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION (Annex)

No.: 2021312308000114

Page 1 of 5

Product information:

1. This certificate covers the following models:

- 8571/**-***-*(-*)

Nomenclature:

8571	/	*	*	-	*	**	-	*	(-*)
a	/	b	c	-	d	e	-	f	g

a: Type series

b: Design

1 = Standard

2 = North America

c: Device

1 = Wall mounting socket

6 = Coupler socket

d: Numbers of Poles:

4 = 3P + PE

5 = 3P + N + PE

e: Code for pin Orientation and voltage

f: B: silicone free

S =Silicone

g: Denotes any number or character (Not affecting Ex performance)

Ambient temperature:

For Wall Socket type 8571/*1-***-*(-*) and Coupler Socket type 8571/*6-***-*(-*):

-50°C ≤ Tamb ≤ +25°C...65°C / T6 ... T5 by current range 16 A...32A

-50°C ≤ Tamb ≤ +25°C...60°C / T6 ... T5 by current range 16 A...32A valid for use of

Issued date: 2023-04-24

Director:



Nanyang Explosion Protected Electrical
Apparatus Research Institute Co.,Ltd.





CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

(Annex)

No.: 2021312308000114

Page 2 of 5

metal plate or terminal of auxiliary contact with adhesive D0213

Service temperature:

For Wall Socket type 8571/*1-***-*(-*) and Coupler Socket type 8571/*6-***-*(-*):

-50°C ≤ Ts ≤ +60°C (valid for use of metal plate or terminal of auxiliary contact with adhesive D0213)

-50°C ≤ Ts ≤ +75°C (for the enclosure)

-50°C ≤ Ts ≤ +95°C (valid for contact sleeve carrier)

Electrical Data:

	Main contacts	Auxiliary contacts
	4, 5 poles	
Max. rated operational voltage	690V AC/110V DC	500V AC/110V DC
Max. rated insulation voltage	750V AC	550V AC
Max. rated operational current	32A	6A
Switching capacity	AC-3, 690 V, 32 A 7.5 kW, 220 - 240 V 15 kW, 380 - 415 V 30 kW, 600 - 690 V DC-1, 110 V, 32 A	AC-15, 500 V, 1250VA AC-15, 230 V, 1380VA AC-12, 500 V, 3000VA DC-13, 110 V, 110 W
Max. rated frequency	0-500Hz	
Short-circuit protection	35A gG (with thermal protection)	

Issued date: 2023-04-24

Director:



Nanyang Explosion Protected Electrical Apparatus Research Institute Co.,Ltd.



http://www.ccc-cnex.com
ccc.china-ex.com

Add: No. 20, North Zhongjing Road, Nanyang, Henan, P. R. China
Tel: 0377-63239734

P.C.: 473008

Email: ccc@cn-ex.com



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION (Annex)

No.: 2021312308000114

Page 3 of 5

Terminal capacity for Flange socket type 8571/*5-**	1 or 2 x 2.5—10 mm ² (12...8 AWG)solid 1 or 2 x 2.5—6 mm ² (12...10 AWG)stranded
Terminal capacity for auxiliary contacts	1 or 2 x 0.5...2.5 mm ² (20...14 AWG)solid or stranded
PE conductor size	Same or larger than line / load cross section
Tightening torque	Terminals: max.1.6Nm, for 2 x 10mm ² : 2Nm Fixing screws of the flange socket: max.2.3Nm Fixing screws of the enclosure cover: max.1.8Nm

Note: Stranded wires are suitable with or without wire end ferrules.

Ingress protection: IP64

(Cover must be closed properly when plug is not inserted to maintain ingress protection. The plug shall be free from water and dust before is inserted to the flange socket.)

Ex marking: Ex db eb IIC T6/T5 Gb, Ex tb IIIC T76°C Db

- Producers should organize production in accordance with the technical documents approved by the certification body.

2. Specific conditions of safety use:

- Openings that are not used must be closed in compliance with the specifications of the Standards, and CCC certified cable gland or stopping plug must be applied(as applicable).

- In order to ensure the ingress protection IP, the bayonet ring of the plug must be screwed up to the stop to the socket or the hinged cover of the socket must be closed and screwed up to the stop when the plug is not inserted. The cover of the terminal compartment must be fastened with the appropriate torque.

Issued date: 2023-04-24

Director:



Nanyang Explosion Protected Electrical
Apparatus Research Institute Co.,Ltd.





CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION (Annex)

No.: 2021312308000114

Page 4 of 5

- The wall socket must not be used in dust areas where highly charge-generating processes, machine friction and separation processes, electron spraying (e.g. around electrostatic coating systems) and pneumatically conveyed dust occur.
- The connecting cable of the wall socket or the coupler socket type 8571/**-***-*(-*) shall be fixed and routed so that it will be adequately protected against mechanical damage.
- If the temperature at the input parts exceeds 70°C, temperature-resistant connecting cables shall be used.
- Installation of electrical components requires a further assessment by an ExCB.
- The user shall be informed of the following conditions in an appropriate form, e.g. with a note included in the operating instructions:
 - WARNING – DO NOT OPEN WHEN ENERGIZED.
 - WARNING – POTENTIAL ELECTROSTATIC CHARGING HAZARD – SEE INSTRUCTIONS
 - WARNING – IN ORDER TO ENSURE THE INGRESS PROTECTION IP, THE BAYONET RING OF THE PLUG MUST BE SCREWED UP TO THE STOP TO THE SOCKET AND THE HINGED COVER OF THE SOCKET MUST BE CLOSED AND SCREWED UP TO THE STOP WHEN THE PLUG IS NOT INSERTED. THE COVER OF THE TERMINAL COMPARTMENT MUST BE FASTENED WITH THE APPROPRIATE TORQUE.
 - WARNING –TEMPERATURE AT THE ENTRY POINTS HIGHER THAN +70°C. A PROPER SELECTION OF CABLE AND CABLE GLANDS OR CONDUITS IN CONDUIT IS REQUIRED
- See instruction for other information.

3. Certificate related report(s):

Issued date: 2023-04-24

Director:



Nanyang Explosion Protected Electrical
Apparatus Research Institute Co.,Ltd.





CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION (Annex)

No.: 2021312308000114

Page 5 of 5

- Type test report: CQST2112C002, CQST2112C002/01
- Factory inspection report: CN2022Q030187

4. Certificate change information:

- 1st change on April 24, 2023:

- (1) Updated the standards for certification.
- (2) Changing the model form 8571/**-***-S*** to 8571/**-***-*(-*).

Issued date: 2023-04-24

Director:



Nanyang Explosion Protected Electrical
Apparatus Research Institute Co.,Ltd.



<http://www.ccc-cnex.com>
ccc.china-ex.com

Add: No. 20, North Zhongjing Road, Nanyang, Henan, P. R. China
Tel: 0377-63239734

P.C.: 473008

Email: ccc@cn-ex.com