



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

CERTIFICATE NO.: 2021322316003893

NAME AND ADDRESS OF THE APPLICANT

R.STAHL Schaltgeräte GmbH
Am Bahnhof 30, 74638, Waldenburg, Germany

NAME AND ADDRESS OF THE MANUFACTURER

R.STAHL Schaltgeräte GmbH
Am Bahnhof 30, 74638, Waldenburg, Germany

NAME AND ADDRESS OF THE FACTORY

R.STAHL Schaltgeräte GmbH
Am Bahnhof 30, 74638, Waldenburg, Germany

NAME, SERIES, MODEL AND SPECIFICATION

Digital output module with valve
9478/22-08-51

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T 3836.1-2021、GB/T 3836.4-2021

This is to certify that the above-mentioned product(s) complies with the requirements of implementation rules for compulsory certification (CNCA-C23-01:2024).

Issue date:2026-04-08 Valid until:2031-04-07

Date of initial issue:2021-04-12

Type of Certification: Type test + Initial inspection + Surveillance inspection

The certificate details and validity can be verified by scanning the QR code below or logging into the issuing authority's official website. It can also be inquired on the CNCA website (www.cnca.gov.cn).

(In case of dispute, the Chinese text shall prevail.)



SITIIAS
Worldwide Access

APPROVAL:



Shanghai Inspection and Testing Institute of Instruments and Automation Systems Co., Ltd.



中国国家强制性产品认证证书

证书编号: 2021322316003893

认证委托人名称及地址
R.STAHL Schaltgeräte GmbH
Am Bahnhof 30, 74638, Waldenburg, Germany

生产者名称及地址
R.STAHL Schaltgeräte GmbH
Am Bahnhof 30, 74638, Waldenburg, Germany

生产企业名称及地址
R.STAHL Schaltgeräte GmbH
Am Bahnhof 30, 74638, Waldenburg, Germany

产品名称和系列、型号、规格
数字输出阀模块
9478/22-08-51

产品标准和技术要求
GB/T 3836.1-2021、GB/T 3836.4-2021

上述产品符合《强制性产品认证实施规则 防爆电气》
(CNCA-C23-01:2024)的要求, 特发此证。
发证日期:2026年04月08日 有效期至:2031年04月07日

首次发证日期:2021年04月12日
认证模式:型式试验+初始工厂检查+获证后监督

证书信息和有效性可扫描下方二维码或登录发证机构网站查验,
也可在认监委网站 (www.cnca.gov.cn) 查询。



批准:



上海仪器仪表自控系统检验测试所有限公司



中国国家强制性产品认证证书

证书编号：2021322316003893

证书附页：第 1 页 共 1 页

产品名称：
数字输出阀模块

型号规格：
9478/22-08-51

防爆标志：
Ex ib II C T4 Gb

电气参数：
连接器 X2 的端子 1(正极)和端子 2(负极)
 $U_o=6.6V$
 $I_o=67mA$
 $P_o=110mW$

	II B			II C		
$L_o[mH]$	20	1	0.1	10	1	0.1
$C_o[uF]$	5.2	12	24	0.84	2.1	3.9

相关报告编号：
2023S17402-011308、2020S17402-002781

使用条件：
1. 特殊（限制）使用条件：
1) 产品使用环境温度范围为-20℃~+60℃。
2) 产品安装在爆炸性 1 区危险场所时，应安装在符合 GB/T 3836.3-2021 标准要求的外壳中。

本页为证书附页，应与证书主页同时使用。



SITIAS
Worldwide Access

批准：

郭俊华



上海仪器仪表自控系统检验测试所有限公司