

CERTIFICATE OF COMPLIANCE

Certificate Number E307783
Report Reference E307783-20071129
Issue Date 2020-APRIL-10

Issued to: R. STAHL Schaltgeraete GmbH
Am Bahnhof 30
74638 Waldenburg GERMANY

**This certificate confirms that
representative samples of**

ENCLOSURES FOR USE IN HAZARDOUS LOCATIONS
See Addendum Page

Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.

Standard(s) for Safety:

UL 1203, 5th Ed. Dated 2018-04-30, Explosion-Proof and
Dust-Ignition-Proof Electrical Equipment for Use in
Hazardous (Classified) Locations
CAN/CSA C22.2 No. 25-17, Enclosures for Use in Class II
Groups E, F, and G Hazardous Locations
CAN/CSA C22.2 No. 30-M1986, Rev. 1988-11,
(R2016)Explosion-Proof Enclosures for Use in Class I
Hazardous Locations

Additional Information:

See the UL Online Certifications Directory at
<https://iq.ulprospector.com> for additional information.

This *Certificate of Compliance* does not provide authorization to apply the UL Mark. Only the UL Follow-Up Services Procedure provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



CERTIFICATE OF COMPLIANCE

Certificate Number E307783
Report Reference E307783-20071129
Issue Date 2020-APRIL-10

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Enclosures, Series 8265 followed by /, followed by 6, followed by 1, 2, 3, 4, 5 or 6 may be followed by additional numbers or letters for use in Class I, Division 1, Groups A, B, C and D; Class II, Division 1, Groups E, F and G; and Class III Hazardous Locations. These enclosures are Classified as to explosion and fire hazards only.



Bruce Mahrenholz, Director North American Certification Program
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

