



TYPE APPROVAL CERTIFICATE

Certificate No:
TAE000040T
Revision No:
2

This is to certify:

That the Light Fitting

with type designation(s)
6009/1., 6009/4.

Issued to

R. STAHL Schaltgeräte GmbH
Waldenburg, Germany

is found to comply with

DNV rules for classification – Ships, offshore units, and high speed and light craft

Application :

Product(s) approved by this certificate is/are accepted for installation on all vessels classed by DNV.

Type	Vibration class	Degree of protection	Temp. class	Voltage (V)	Suitable for Hazardous areas
6009/1.	A	IP 66/67	D	See Page 2	See Page 2
6009/4.	A	IP 66/67	D	See Page 2	See Page 2

Issued at **Høvik** on **2023-12-15**

This Certificate is valid until **2025-07-30**.

for **DNV**

DNV local unit: **Augsburg**

Approval Engineer: **Maik Gagern**

Oddvar Deinboll
Head of Section

This Certificate is subject to terms and conditions overleaf. Any significant change in design or construction may render this Certificate invalid. The validity date relates to the Type Approval Certificate and not to the approval of equipment/systems installed.

LEGAL DISCLAIMER: Unless otherwise stated in the applicable contract with the holder of this document, or following from mandatory law, the liability of DNV AS, its parent companies and their subsidiaries as well as their officers, directors and employees ("DNV") arising from or in connection with the services rendered for the purpose of the issuance of this document or reliance thereon, whether in contract or in tort (including negligence), shall be limited to direct losses and under any circumstance be limited to 300,000 USD.



Form code: TA 251

Revision: 2022-12

www.dnv.com

Page 1 of 3

Product description*

LED Emergency Light Fitting

Series 6009/1.
 Power supply: 110 ... 240V AC, 50/60 Hz
 110 ... 250V DC
 Type 6009/12.: P ≤ 28W
 Type 6009/14.: P ≤ 52W

Series 6009/4.
 Power supply: 100 ... 240V AC, 50/60 Hz
 110 ... 250V DC
 Type 6009/412.: P ≤ 28W
 Type 6009/414.: P ≤ 52W

Degree of protection: IP 66/67

Explosion Protection*:

Type 6009/1..1.:	 II 2G Ex db eb mb op is IIB+H ₂ T4 Gb	
Type 6009/1..2.:	 II 2G Ex db eb mb op is IIC T4 Gb	
Type 6009/4.:	 II 2G Ex db eb ib mb op is IIC T4 Gb	(Type 6009/4.)
	 II 2G Ex db eb ip op is IIC T4 Gb	(Type 6009/4. incl. 6046/3.)
All types:	 II 2D Ex tb op is IIIC T100°C Db	

Application/Limitation

This Certificate is issued based on DNV Class Programme DNV-CP-0338, Edition September 2021.

Maker's instructions are to be observed.

*Note: All details about electrical explosion protection mentioned in this certificate are for information only. For relevant binding information the corresponding Certificate of Conformity with regard to electrical explosion protection, issued by a recognised Authority, shall be observed.

Location Classes:

Vibration: A
 Humidity: B
 Temperature: D
 EMC: A

Type Approval documentation

Tests carried out

Applicable tests according to DNV Class Guideline DNV-CG-0339, Edition August 2021

Marking of product

Maker's trademark
 Type designation
 Rated Voltage
 Electrical explosion protection: Type of protection and marking according to the applicable Certificate of Conformity *

Periodical assessment

The scope of the periodical assessment is to verify that the conditions stipulated for the Type approval are complied with and that no alterations are made to the product design or choice of materials.

The main elements of the assessment are:



Job Id: **262.1-032363-2**
Certificate No: **TAE000040T**
Revision No: **2**

- Inspection on factory samples, selected at random from the production line (where practicable)
- Results from Routine Tests (RT) checked (if not available tests according to RT to be carried out)
- Review of type approval documentation
- Review of possible change in design, materials and performance
- Ensuring traceability between manufacturer's product type marking and Type Approval Certificate.

Periodical assessment is to be performed after 2 years and after 3.5 years. A renewal assessment will be performed at renewal of the certificate.

END OF CERTIFICATE